MODEL: MD6P-24


# **Lightning Surge Protectors for Electronics Equipment M-RESTER**

## LIGHTNING SURGE PROTECTOR FOR STANDARD SIGNAL LINE & PULSE USE

(conduit mount, weather-proof, 24 V DC line voltage)

#### **Functions & Features**

- Designed specifically for 4 20 mA DC and pulse signal line including both 4-wire and 2-wire transmitters
- Direct mount in a wiring conduit of outdoor enclosures
- Absorbs surges only without affecting instrumentation signal



## MODEL: MD6P-24-[1][2][3]

■ SELECTABLE WIRING CONDUITS SPECIFIC TO EACH APPROVAL 'N' marked combinations are not selectable.

APPROVAL WIRING CONDUIT	0	3	4
0	Υ	N	N
1	Υ	Υ	Υ
2	Υ	N	Υ

#### **ORDERING INFORMATION**

• Code number: MD6P-24-[1][2][3]

Specify a code from below for each of [1] through [3]. (e.g. MD6P-24-00B)

For the safety approval code 4, specify the product's destination country using Ordering Information Sheet (No. ESU-8284).

### [1] SAFETY APPROVAL

0: None

3: FM explosion-proof

4: ATEX flameproof

Confirm selectable combinations of approval and wiring conduit types in the table.

### **[2] WIRING CONDUIT**

0: G 1/2

1: 1/2 NPT

2: M20 × 1.5

Confirm selectable combinations of approval and wiring conduit types in the table.

### [3] BODY MATERIAL

B: Brass

S: Stainless steel

### **GENERAL SPECIFICATIONS**

Degree of protection: IP65

Wiring conduit: See 'Ordering information.'

**Electrical connection**: Leadwires

Leadwire diameters

Cable side & grounding: AWG20 Protected equipment side: AWG22

Body material: Nickel-plated brass or stainless steel 316

#### **INSTALLATION**

Operating temperature:

No Safety approval:  $-40 \text{ to } +85^{\circ}\text{C} \text{ (}-40 \text{ to } +185^{\circ}\text{F)}$ 

FM approval:

 $-40 \text{ to } +80^{\circ}\text{C} \text{ (-40 to } +176^{\circ}\text{F) (T6)}$ 

ATEX approval:

 $-40 \text{ to } +80^{\circ}\text{C} (-40 \text{ to } +176^{\circ}\text{F}) (T5)$ 

 $-40 \text{ to } +75^{\circ}\text{C} (-40 \text{ to } +167^{\circ}\text{F}) (T6)$ 

Mounting: Screwed into an electrical conduit of outdoor

enclosures

Weight: 300 g (0.66 lb)

#### **PERFORMANCE**

Discharge voltage (peak voltage)

Line to line: 30 V min. Line to ground: ±160 V min.

Max. surge voltage

Line to line: 40 V max. Line to ground: ±650 V max.

(The maximum voltage that could pass through the surge protector. Protected equipment must be able to withstand

this voltage for a very short time period.)

Response time:

Line to line:  $\leq$  4 nsec. Line to ground:  $\leq$  20 nsec.

Leakage current:

Line to line:  $\leq$  5  $\mu$ A @ 30 V DC Line to ground:  $\leq 5 \mu A @ \pm 160 \text{ V DC}$ 

Discharge current capacity: 10000 A (8/ 20 µsec.)

Max. load current: 100 mA



MD6P-24 SPECIFICATIONS

ES-8285 Rev.11 Page 1/3

MODEL: MD6P-24

**Internal series resistance**: Approx. 22  $\Omega$  including return

Max. line voltage

Without safety approval: 30 V DC With safety approval: 28 V DC

Capacitance @ 1 kHz: Line to line: ≤ 2500 pF Line to ground: ≤ 100 pF

### **STANDARDS & APPROVALS**

EU conformity:

**ATEX Directive** 

Ex db EN 60079-1

**EMC Directive** 

EMI EN 61000-6-4

EMS EN 61000-6-2

**RoHS Directive** 

#### Safety approval:

FM: Explosion-proof and Dust-ignition proof

Class I, Div. 1, Groups A, B, C and D

Class II, Div. 1, Groups E, F and G

Class III, Div. 1

T6


(Class 3615)

ATEX: Flameproof

(a) II 2G, Ex db IIC, T5 and T6 Gb

(EN 60079-1)

### **CONNECTION EXAMPLES**




Connect the MD6P's green leadwire to the ground terminal inside the protected equipment enclosure to ground through the enclosure's outside ground terminal.

If the enclosure does not have an inside ground terminal, connect the green leadwire directly to the outside ground wire pulled inside the enclosure. Keep the ground wire as short as possible.




MODEL: MD6P-24

### **EXTERNAL DIMENSIONS** unit: mm [inch]



# **SCHEMATIC CIRCUITRY & CONNECTION DIAGRAM**



\*1. The zenor diode has polarity. Zero-cross signal cannot be connected.



Specifications are subject to change without notice.

